



NOTE:

- FOR INSTALLATIONS BEHIND CURB USE 36-H-POLYMER METER BOX IN LIEU OF GATE BOX AND SET TOP OF ANGLE VALVE 4 INCH BELOW SURFACE.

BLOW OFF ASSEMBLY AT DEAD END MAIN

WDS -112



**LONG BEACH
WATER DEPARTMENT**

RECOMMEND

Robert J. [Signature]

DIVISION ENGINEER

APPROVED

[Signature]

DIRECTOR OF ENGINEERING

DATE: 11/11/14

SCALE: N.T.S.

SHEET 1 OF 1