

Annual Water Quality Report

WATER TESTING PERFORMED IN 2018

PROUDLY PRESENTED BY:

Long Beach Water Department
Award Winning Members of
Partnership for Safe Water (AWWA)
PWS ID#: 1910065

Long Beach Board of Water Commissioners:
Gloria Cordero, *President*
Harry Saltzgaver, *Vice President*
Frank Martinez, *Secretary*
Robert Shannon, *Commissioner*
Art Levine, *Commissioner*



MESSAGE FROM THE GENERAL MANAGER



Dear Customer:

LBWD takes our responsibilities to our community very seriously.

To safeguard our continued exceptional water quality for nearly half a million customers, our skilled staff ensure that the water we serve meets or exceeds all federal and state water quality standards. Our water quality staff performed over 70,000 tests in 2018 and analyzed the samples for more than one hundred drinking water contaminants.

We are proud to provide our customers with reliable, affordable, and exceptional quality drinking water. Should you have any questions or concerns, please feel free to call our Water Quality Laboratory at 562.570.2482 for more information. In addition, we always welcome your comments and suggestions at our Board of Water Commissioner meetings. Please visit lbwater.org to view the upcoming meeting schedule.

We appreciate your reading the annual water quality report. Thank you for your time and interest.

Sincerely,

Chris Garner

WE ARE PROUD TO PROVIDE OUR CUSTOMERS WITH RELIABLE, AFFORDABLE AND EXCEPTIONAL QUALITY DRINKING WATER.



Consumer Confidence Report 2018

The **Long Beach Water Department** is pleased to inform you that your tap water met all United States Environmental Protection Agency and State of California drinking water standards for 2018.

CCR DELIVERY

The Consumer Confidence Report, or CCR, is an annual drinking water quality report that the **Safe Drinking Water Act (SDWA)** requires public water systems to provide each customer. The purpose of the CCR is to inform customers about the quality of their drinking water, where their drinking water comes from, what it takes to deliver water to businesses and homes and the importance of protecting drinking water sources.

LBWD will publish the 2018 CCR electronically at lbwater.org/annual-water-quality-report. If you would prefer to receive a hard copy of the CCR, please contact us at 562.570.2482 to request a copy or visit your neighborhood Long Beach Library branch.


El Reporte de Confianza de los Consumidores, o CCR, es un informe anual de la calidad de agua potable que la **Ley de Agua Potable Segura (SDWA)** requiere LBWD para ofrecer a cada cliente. El propósito de la CCR es para aumentar la conciencia de los consumidores acerca de la calidad de su agua potable, de donde proviene, lo que se necesita para suministrar agua a las empresas y los hogares y la importancia de proteger fuentes de agua potable.

El LBWD publicará el CCR del 2018 electrónicamente, en lbwater.org/annual-water-quality-report. Si prefiere recibir una copia impresa del reporte CCR, póngase en contacto con LBWD por teléfono al 562.570.2482 para solicitar una copia o visite a una biblioteca de Long Beach en su vecindad.



LONG BEACH DRINKING WATER SOURCES

During 2018, approximately 58 percent of the potable water served by LBWD was supplied by local groundwater; the remaining 42 percent was supplied through purchased, imported surface water. LBWD purchases treated surface water from the Metropolitan Water District of Southern California (MWD) and treats the groundwater pumped from active wells around the Long Beach and Lakewood area at our Groundwater Treatment Plant. Both the purchased surface water quality and the treated groundwater quality surpass the federal and state drinking water standards.



The federal regulations are set by the U.S. Environmental Protection Agency (US-EPA), and the state standards are set by the State Water Resources Control Board (State Board) Division of Drinking Water.

Two major aqueducts supply the surface waters feeding MWD’s five regional treatment plants. Colorado River water, which has the higher mineral content of the two supplies, is brought into Southern California through the 242-mile long Colorado River Aqueduct (CRA). This aqueduct, constructed and operated by MWD, originates at Lake Havasu and terminates in Southern California at Lake Mathews. State Water Project (SWP) water, which contains a lower mineral content but higher natural organic matter content, is conveyed through the California Aqueduct. This aqueduct, constructed and operated by the California Department of Water Resources, transfers water originating from Lake Oroville in Northern California through 441 miles before terminating in Southern California.

The groundwater treated at the LBWD Groundwater Treatment Plant originates from the San Gabriel watershed.

BOTH THE PURCHASED SURFACE WATER QUALITY AND THE TREATED GROUNDWATER QUALITY SURPASS THE FEDERAL AND STATE DRINKING WATER STANDARDS.



The watershed is fed by rain and snowmelt and flows through washes and creeks into the San Gabriel River and Whittier Narrows before percolating into the underground aquifer of the central basin area of Los Angeles. The City of Long Beach is a part of the Central Basin service area.

For hydraulic reasons, the Long Beach service area may be divided into two main regions: the MWD zone, which primarily receives purchased, treated surface water, and the blended zone, which may receive a combination of treated groundwater and purchased, treated surface water. LBWD

sometimes changes the blends of water in our system, and the residents may notice the associated mineral content (referred to as hardness) changes to the water quality.

58%
OF POTABLE WATER SERVED BY
LBWD WAS SUPPLIED BY LOCAL
GROUNDWATER

Regardless of the area in Long Beach that you work or live in, LBWD's goal is to provide water that meets or surpasses all water quality regulations at the most reasonable cost to our customers. *Figure 1.0* shows the areas that may be affected by a change in the water blend.

INFORMATION ABOUT DRINKING WATER CONTAMINANTS

Drinking water sources (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As the water travels over the surface of the land or through the ground, the water dissolves naturally occurring minerals - sometimes including radioactive material - and can also pick up substances resulting from the presence of animals and human activity.

In order to ensure that tap water is safe to drink, the US-EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the US-EPA's **Safe Drinking Water Hotline** (1.800.426.4791).



IMMUNO-COMPROMISED PEOPLE

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised people (i.e. those with cancer taking chemotherapy, who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants) can be particularly at risk from infections. Immuno-compromised people should seek advice about drinking water from their health care providers. **US-EPA/Centers for Disease Control (CDC)** guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline.

**SAFE
DRINKING
WATER
HOTLINE
1.800.426.4791**

Natural Contaminants Present in Source Water Prior to Treatment May Include:

Biological Contaminants: such as viruses and bacteria may come from sewage treatment plants, septic systems, agricultural, livestock operations and wildlife.

Inorganic Chemicals: such as salts and metals can be naturally occurring or can result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides: may come from a variety of sources such as agriculture, urban storm water runoff and residential uses.

Organic Chemicals: include synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and can also come from gas stations, urban storm water runoff, agricultural applications and septic systems.

Radioactive materials: can be naturally occurring or can be the result of oil and gas production and mining activities.



SOURCE WATER ASSESSMENT

As required under the **1996 Safe Drinking Water Act** amendments, a source water assessment must be completed for all active drinking water sources.

The goal of the source water assessment is to inventory all potential activities that may lessen the source water quality. LBWD purchased water in 2018 from the Metropolitan Water District of Southern California (MWD) and City of Lakewood. MWD completed its source water assessment of its Colorado River and State Project water supplies in December 2002. The Colorado River supplies are most vulnerable to recreation, urban/storm water runoff, and increasing urbanization in watershed and wastewater. State Water Project water supplies are considered most vulnerable to urban/storm water runoff, wildlife, agriculture, recreation and wastewater. A copy of the assessment can be obtained by contacting MWD at 213.217.6850.



The City of Lakewood Department of Water Resources completed an assessment in 2003 of all drinking water wells that served the city's drinking water system. The sources are considered most vulnerable to current and historic gas stations, repair shops, storage tanks and dry cleaners. A copy of the complete assessment is available at the Lakewood City Clerk's Office at 5050 Clark Avenue or by contacting the Lakewood Department of Water Resources, at 562.866.9771, extension 2700.

LBWD completed a new source water assessment on its active wells in July 2012. New wells that are constructed after this date must also undergo a similar assessment. The assessment concluded that all active wells are considered most

vulnerable to the community sewer collection system. Depending on location, some wells are considered vulnerable to gas stations, dry cleaners, leaking underground fuel tanks, airport activities, metal plating/finishing/fabrication, plastic/synthetics producers and historic landfills. Although the wells are considered vulnerable to the aforementioned activities, the LBWD performs water quality monitoring for each active well and has not detected any constituents that suggests contamination. It is noteworthy to point out that the physical barrier (well containment) has a high effectiveness against these contaminations.

Please contact the LBWD by phone at 562.570.2482 for more details or if you would like to review the assessment document.



Sampling Results



DURING THE PAST YEAR, WE HAVE TESTED OVER 70,000 WATER SAMPLES IN ORDER TO DETERMINE THE PRESENCE OF ANY RADIOACTIVE, BIOLOGICAL, INORGANIC, VOLATILE ORGANIC, OR SYNTHETIC ORGANIC CONTAMINANTS.

Even though all the substances in these tables are under the maximum contaminant level (MCL), it is important to include in this report the list of drinking water contaminants detected during the 2018 calendar year. **The presence of these substances in the water does not necessarily indicate that the water poses a health risk.** Unless otherwise noted,

the data presented in this table are from the testing performed from January 1 to December 31, 2018. The State requires us to monitor for certain substances less than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

SECONDARY DRINKING WATER STANDARDS - Aesthetic Standards, 2018

PARAMETER (UNIT OF MEASURE)	2 ND MCL	MWD ZONE (114)			BLENDED ZONE (325)			TYPICAL SOURCES OF CONTAMINATION
		AVE.	MAX	RANGE	AVE.	MAX	RANGE	
Chloride (ppm)	500	88	103	52-103	52	60	42-60	Runoff/leaching from natural deposits; seawater influence
Color (CU)	15	1	2	ND-2	2	3	ND-3	Naturally-occurring organic materials
Specific Conductance (µS/cm)	1600	795	998	412-998	509	626	424-626	Substances that form ions when dissolved in water; seawater influence
Odor ³ (TON)	3	2	NA	NA	2	NA	NA	Naturally-occurring organic materials
Sulfate (ppm)	500	167	250	67-250	55	82	26-82	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	1000	509	639	279-639	318	371	264-371	Runoff/leaching from natural deposits



REGULATED PRIMARY HEALTH STANDARDS, 2018

PARAMETER (UNIT OF MEASURE)	GOALS	REGULATORY LEVELS			MWD ZONE (114)			BLENDED ZONE (325)			TYPICAL SOURCES OF CONTAMINATION
	PHG (MCLG)	MCL	2 nd MCL	NL (AL)	AVE	MAX	RANGE	AVE	MAX	RANGE	
CLARITY											
Turbidity ² (NTU)	NA	TT	5	NS	ND	0.10	ND-0.10	ND	0.09	ND-0.09	Soil Runoff
Turbidity ² (Lowest monthly percent of samples meeting limit) = 100%											
MICROBIOLOGY (% POSITIVE)											
Total Coliform Bacteria ⁴	(0)	5%	NS	NS	City-Wide: Highest Monthly-0.70%; Range ND-0.70%					Naturally present in the environment	
INORGANIC CHEMICALS											
Aluminum (ppb)	600	1000	200	NS	115	236	36-236	43	187	ND-187	Erosion of natural deposits, added during water treatment
Arsenic (ppb)	0.004	10	NS	NS	ND	2	ND-2	ND	ND	ND	Erosion of natural deposits, runoff from orchards and industrial process
Copper ¹ (ppb)	300	NS	1000	(1300)	City-wide: 90 th percentile = 144, 149 sites sampled; 0 sites over Action Level (AL = 1300)					Corrosion of plumbing, erosion of natural deposits	
Fluoride (ppm)	1	2	NS	NS	0.8	0.9	0.7-0.9	0.7	0.8	0.7-0.8	Erosion of natural deposits, supplemental additive
Lead ¹ (ppb)	0.2	NS	NS	(15)	City-wide: 90 th percentile = <DLR, 149 sites sampled; 0 sites over Action Level (AL = 15)					Internal corrosion of household plumbing, erosion of natural deposits	
Nitrate (N) (ppm)	10	10	NS	NS	0.4	0.7	ND-0.7	ND	0.4	ND-0.4	Erosion of natural deposits; runoff from fertilizer use and septic systems



UNREGULATED CHEMICALS REQUIRING MONITORING UNDER FEDERAL UCMR3, 2013-2014

PARAMETER (UNIT OF MEASURE)	HA	MCL (NL)	PHG	MWD ZONE (114)			WTP EFFLUENT			DSMRT		
	PPB	PPB	PPB	AVE	MAX	RANGE	AVE	MAX	RANGE	AVE	MAX	RANGE
Chlorate (ppb)	NS	(800)	NS	92	110	78-110	ND	ND	ND	53	64	31-64
Hexavalent Chromium (ppb)	NS	NS	0.02	0.063	0.074	0.053-0.074	ND	0.032	ND-0.032	0.045	0.067	ND-0.067
Molybdenum (ppb)	40	NS	NS	4.3	4.7	4.0-4.7	6.9	7.1	6.7-7.1	5.5	6.2	4.8-6.2
Strontium (ppb)	4000	NS	NS	890	970	810-970	170	180	160-180	645	750	530-750
Vanadium (ppb)	NS	(50)	NS	2.6	2.9	2.3-2.9	0.4	0.41	0.4-0.41	1.8	2.4	1.4-2.4

DSMRT = Distribution System Maximum Retention Time (distribution system site farthest from the drinking water utility)
HA = Health Advisories;
WTP = Water Treatment Plant

Unregulated contaminant monitoring under the US-EPA helps to determine where certain contaminants occur and whether the contaminants need to be regulated. This unregulated contaminant monitoring under Federal UCMR 3 was done in 2013-2014. LBWD will report this same result each CCR year (2016, 2017, 2018 and 2019) until 5 years of recommended reporting is completed.

RADIOLOGICALS, 2018

PARAMETER (UNIT OF MEASURE)	GOALS	REGULATORY LEVELS			MWD ZONE (114)			BLENDED ZONE (325)			TYPICAL SOURCES OF CONTAMINATION
	PHG (MCLG)	MCL	2 ND MCL	NL (AL)	AVE.	MAX	RANGE	AVE.	MAX	RANGE	
Gross Alpha (GA) ³ Particle Activity (pCi/L)	(0)	15	NS	NS	MWD plant effluents Gross Alpha detected in the range of ND - 4 pCi/L. ⁶ Gross Alpha was not detected in the MWD Zone of LBWD distribution in 2018.						Erosion of natural deposits
Gross Beta (GB) ³ Particle Activity (pCi/L)	(0)	50	NS	NS	MWD plant effluents Gross Beta detected in the range of ND - 5 pCi/L. ⁶ Gross Beta was detected at 3.5 pCi/L in the LBWD distribution in 2018.						Decay of natural and man-made deposits
Uranium (pCi/L) ³	0.43	20	NS	NS	MWD plant effluents Uranium detected in the range of ND - 3 pCi/L. ⁶ Uranium was detected at 1.3 pCi/L in the MWD Zone of LBWD distribution in 2018.						Erosion of natural deposits

HEALTH EFFECTS LANGUAGE: Certain minerals are radioactive and may emit forms of radiation known as alpha, beta and photons. Some people who drink water containing alpha, beta and photon emitters in excess of the MCL over many years may have an increased risk of getting cancer. SWRCB considers 50 pCi/L to be the level of concern for beta particles.



UNREGULATED CONTAMINANTS WITH NL, BUT NO MCLS, 2018

PARAMETER (UNIT OF MEASURE)	GOALS	REGULATORY LEVELS			MWD ZONE (114)		BLENDED ZONE (325)		TYPICAL SOURCES OF CONTAMINATION
	PHG (MCLG)	MCL	2 ND MCL	NL (AL)	RESULT	RANGE	RESULT	RANGE	
Boron ³ (ppb)	NS	NS	NS	1000	120	NA	140	NA	Naturally present in the environment
Chlorate ³ (ppb)	NS	NS	NS	800	ND	MWD system-wide ⁵ : ND -43	31	NA	Byproduct of drinking water chlorination; industrial processes
Formaldehyde ³ (ppb)	NS	NS	NS	100	6.9	NA	12	NA	Possible byproduct of drinking water ozonation
Nitrosodimethylamine (NDMA) ³ (ppt)	3	NS	NS	10	2.3	MWD system-wide ⁵ : ND -4.1	5.7	NA	Formed through natural, industrial and disinfection processes

ADDITIONAL CONSTITUENTS OF INTEREST, 2018

PARAMETER (UNIT OF MEASURE)	MWD ZONE (114)			BLENDED ZONE (325)		
	AVE.	MAX	RANGE	AVE.	MAX	RANGE
Alkalinity (ppm)	99	119	73-119	124	136	118-136
Calcium (ppm)	47	70	24-70	27	35	13-35
Hardness (ppm)	200	278	108-278	97	129	53-129
Hardness (gpg)	12	16	6.3-16	5.7	7.6	3.1-7.6
Magnesium (ppm)	20	25	11-25	7.0	11	3.8-11
pH (field)	8.22	8.61	8.03-8.61	8.26	8.63	8.08-8.63
Potassium (ppm)	4.0	5.0	2.7-5.0	2.0	2.6	1.7-2.6
Silica (ppm)	9	11	7.6-11	17	22	13-22
Sodium (ppm)	76	97	47-97	67	74	58-74



DISINFECTION BYPRODUCTS AND MAXIMUM RESIDUAL DISINFECTANTS, 2018

PARAMETER (UNIT OF MEASURE)	GOALS	REGULATORY LEVELS			MWD ZONE (114)	BLENDED ZONE (325)	TYPICAL SOURCES OF CONTAMINATION
	PHG (MCLG)	MCL	2 ND MCL	NL (AL)			
Bromate (ppb)	0.1	10	NS	NS	MWD Jensen plant effluent running annual average (RAA) was 5.2 ppb in 2018; LBWD distribution system RAA was 5.9 ppb in 2018	Byproduct of drinking water ozonation	
Haloacetic Acids (HAA5) (ppb)	NS	60	NS	NS	City-wide: 9.7 ppb highest LRAA, range: 4.6 - 13 ppb	Byproduct of drinking water chlorination	
Total-Trihalomethanes (TTHM) (ppb)	NS	80	NS	NS	City-wide: 36 ppb highest LRAA, range: 27 - 47 ppb	Byproduct of drinking water chlorination	
Chloramines (ppm)	MRDL=4.0 (as Cl ₂)	MRDLG=4.0 (as Cl ₂)	NS	NS	City-wide: 2.03 ppm highest running annual average, HRAA; range: 0.63 - 2.65 ppm	Drinking water disinfectant added during treatment	

FOOTNOTES:

1. Copper and Lead - lead and copper are regulated as Treatment Technique under the Lead and Copper Rule, which requires water samples to be collected at the consumers' tap. If action levels are exceeded in more than 10% of consumers' taps, water systems must take steps to reduce these levels. Compliance lead and copper monitoring was conducted in 2016 at 149 consumer taps. The values reported are in compliance with the Lead and Copper Rule. The detection limit for reporting (DLR) lead is 5 ppb. LBWD will report this same result each CCR year (2016, 2017, and 2018) until the next set of samples are taken.
2. Turbidity is a measure of the cloudiness of the water. LBWD monitors it because it is a good indicator of the effectiveness of our filtration system.
3. Single value from LBWD's annual monitoring
4. State Total Coliform Rule and Federal Revised Total Coliform Rule - The State requires, no more than 5.0% total coliform - positive samples found in distribution system in any given month; the new Federal rule requires any positive coliform samples above 5.0% to trigger Level 1 Assessment.
5. Data triennially monitored by MWD (last monitored in 2017)
6. Data from MWD's 2017 system wide monitoring; next monitoring is scheduled for 2020.




INFORMATION ON DETECTED SUBSTANCES

Disinfectants and Disinfection Byproducts (Trihalomethanes, Haloacetic Acids and Bromate)

Disinfection of drinking water was one of the major public health advances in the 20th century. It was a major factor in reducing waterborne diseases caused by pathogenic bacteria and viruses. Long Beach Water Department achieves primary disinfection with free chlorine and utilizes chloramine as a secondary disinfectant in the distribution system. We carefully monitor the amount of disinfectant, adding the lowest quantity of chloramine necessary to protect the safety of your water throughout the distribution system. However, chlorine and chloramine can react with naturally-occurring materials in the water to form disinfection by-products (DBPs).

“LONG BEACH WATER DEPARTMENT ACHIEVES PRIMARY DISINFECTION WITH FREE CHLORINE AND UTILIZES CHLORAMINE AS A SECONDARY DISINFECTANT”





Total Trihalomethanes (TTHMs) and **Haloacetic Acids (HAA5)** are the most common DBPs formed and are suspected to be carcinogenic in humans. Some people consuming water containing TTHM in excess of the MCL over many years may experience liver, kidney, or central nervous system problems, and may have an increased risk of getting cancer.

The values for TTHMs in the distribution system ranged from 27 - 47 ppb, with the highest locational running average (LRAA) of 36 ppb; these values are well below the MCL of 80 ppb. The distribution system HAA5 concentrations ranged from 4.6 - 13 ppb, and the highest LRAA was 9.7 ppb; also well below the MCL of 60 ppb.

DISINFECTION OF DRINKING WATER WAS ONE OF THE MAJOR PUBLIC HEALTH ADVANCES IN THE 20TH CENTURY. IT WAS A MAJOR FACTOR IN REDUCING WATERBORNE DISEASES CAUSED BY PATHOGENIC BACTERIA AND VIRUSES.

Bromate, which is also a disinfection by-product, is formed when ozone reacts with naturally occurring bromide found in the source water. Systems using ozone to treat drinking water are required to monitor for bromate at the treatment plant's effluent. While LBWD does not ozonate our water, purchased treated surface water from MWD may have detectable levels of bromate.

Exposure to high concentrations of bromate over a long period of time was shown to cause cancer in rats and kidney effects in laboratory animals, and it is suspected of potential reproductive effects in humans. US-EPA established a MCL of 10 ppb that it considers protective of non-cancer health effects from long-term exposure in humans.

In 2018, MWD's drinking water bromate levels leaving their treatment plant were reported to be as high as 5.2 ppb (on a highest running annual average basis, HRAA). LBWD can usually decrease the bromate levels in most of our system by blending with our treated groundwater. In 2018, the HRAA for bromate was 5.9 ppb in our distribution system.



Boron

Boron is naturally present in the environment. Based on studies in laboratory animals, exposure to high concentrations of boron in excess of the notification levels (NL) by women who are pregnant may increase their risk of having babies with developmental effects. In 2018, the levels found in LBWD’s water for boron was less than 150 ppb; well below the State’s NL of 1000 ppb.



< 150 ppb
IN 2018, BORON LEVELS IN LBWD’S WATER WAS WELL BELOW THE STATE’S NL OF 1000 ppb

Fluoridation

Fluoride is one of the most plentiful elements on earth. It occurs naturally in water supplies throughout California. Since 1971, LBWD mandated by the Long Beach City Council began adding fluoride to its water.

“FLUORIDATED WATER DOES NOT CHANGE THE TASTE, COLOR OR ODOR OF YOUR WATER.”

Blending fluoridated water from different sources does not increase total fluoride levels in drinking water. Fluoridated water does not change the taste, color or odor of your water. Parents should consult with their child’s doctor or dentist for guidance in supplementing fluoride. In 2015, the U.S. Public Health Services (PHS) revised the recommended fluoride concentration for drinking water to 0.7 mg/L (parts per million [ppm]), to maintain cavity prevention benefits and reduce the risk of dental fluorosis. Consumers may obtain more information about fluoridation, oral health, and current issues at:

waterboards.ca.gov/drinking_water/certlic/drinkingwater/Fluoridation.html



WATER QUALITY STANDARDS: DEFINITIONS, ACRONYMS & ABBREVIATIONS

What are Water Quality Standards?

- AL** **Regulatory Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
- DLR** **Detection Limit for Purpose of Reporting:** The level at which a contaminant is detected for compliance reporting determination
- HRAA** **Highest Running Annual Average**
- LRAA** **Locational Running Annual Average**
- MCL** **Maximum Contaminant Level:** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs (SMCLs) are set to protect the odor, taste, and appearance of drinking water
- MRDL** **Maximum Residual Disinfectant Level:** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants
- NL** **Notification Level:** NLs are health-based advisory levels established by State Board for chemicals in drinking water that lack MCLs. When chemicals are found at concentrations greater than their notification levels, certain requirements and recommendations apply
- NS** **No Standard**
- PDWS** **Primary Drinking Water Standard:** MCLs and MRDLs for contaminants that affect health, along with their monitoring and reporting requirements and water treatment requirements
- RTCR** **Revised Total Coliform Rule**
- TT** **Treatment Technique:** A required process intended to reduce the level of a contaminant in drinking water



WATER QUALITY STANDARDS: DEFINITIONS, ACRONYMS & ABBREVIATIONS

What do the Measurements Mean?

Grains/ Gal	Grains per Gallon: Grains of compound per gallon of water
mg/L	Milligram per Liter (ppm)
µS/cm	Microsiemens per Centimeter: A unit expressing the amount of electrical conductivity of a solution
NA	Not Applicable
ND	Not Detected: Indicates that the substance was not found by laboratory analysis
NTU	Nephelometric Turbidity Units: Measurement of the clarity, or turbidity, of water
PPB	Parts per Billion: One part substance per billion parts water (or micrograms per liter)
PPM	Parts per Million: One part substance per million parts water (or milligrams per liter)
PPT	Parts per Trillion: One part substance per trillion parts water (or nanograms per liter)
TON	Threshold Odor Number: A measure of odor in water

What are Water Quality Goals?

MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. EPA
MRDLG	Maximum Residual Disinfectant Level Goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants
PHG	Public Health Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California EPA

OTHER INFORMATION

Lead and Drinking Water

If elevated levels of lead is present in your water, it can cause serious health problems, especially for pregnant women and young children. It is possible that lead levels in your home may be higher than levels found at your neighbors as a result of the materials used in your home plumbing. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. LBWD is responsible for providing high-quality drinking water, but we cannot control the variety of materials used in home plumbing components. In addition to the 2016 Lead and Copper Rule compliance monitoring at 149 customer taps, LBWD also conducted an extensive study at over 300 additional customer taps for lead and copper and found results to be in compliance with the Lead and Copper Rule. Since 2017, 3 private schools and 72 public schools in the Long Beach Unified School District requested for lead testing at drinking fountains and food preparation faucets. This year (2019), will be our lead and copper compliance monitoring in the City of Long Beach. Please be aware of receiving letters requesting your participation in this monitoring event.

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking (this water can be captured for non-potable use). If you are concerned about lead in your water, you may wish to have your water tested by your utility or an independent laboratory. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the **Safe Drinking Water Hotline** or at: epa.gov/safewater/lead



MINIMIZE THE POTENTIAL FOR LEAD EXPOSURE BY FLUSHING YOUR TAP FOR 30 SECONDS TO 2 MINUTES BEFORE USING IT FOR DRINKING OR COOKING.



1800 E. Wardlow Road Long Beach, CA 90807

*Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.*

Mahalaga ang impormasyong ito. Mangyaring ipasalin ito.

**របាយការណ៍នេះមានព័ត៌មានសំខាន់ៗអំពីទឹកបរិភោគ ។ សូមមកប្រែ
ឬពិគ្រោះជាមួយអ្នកដែលមើលយល់ របាយការណ៍នេះ ។**